



**SOUTH WEST IRRIGATION MANAGEMENT
COOPERATIVE**

**Report to the Department of Health for the Period
01 July 2024 to 30 September 2024**

Rev	Date	Details	Prepared By	Approved By
			Name	Name
1	16/10/2024	Draft	C.Norris	S.Cook
2				
3				
4				

Contents

1	Water Provider Information.....	3
1.1	System Information.....	3
1.1.1	Catchment Details.....	3
1.1.2	Distribution System.....	4
1.1.3	Sampling Schedule & Procedure.....	4
2	Performance Summary.....	5
3	Microbial Performance.....	6
3.1	Microbial – Compliance Summary.....	6
3.2	Microbial – Exception Notifications.....	6
4	Chemical – Health Related Performance.....	7
4.1	Chemical: Health Related – Compliance Summary.....	7
4.2	Chemical: Health Related – Exception Notifications.....	7
5	Chemical – Aesthetic Performance.....	8
5.1	Chemical – Aesthetic.....	8
5.2	Chemical – Aesthetic – Incident Specific Information.....	9
6	Radiological Performance.....	10
6.1	Radiological – Compliance Summary.....	10
7	Planned Sample Summary.....	11
7.1	Planned Sample Compliance Summary.....	11
7.2	Planned Sample Exception Notifications.....	11

1 Water Provider Information

Water Provider Contact Details	
Name of Company	South West Irrigation Management Co-Operative, Trading as Harvey Water
Company Address	1 Turnbull Street, Harvey, WA, 6220
Company Phone	(08) 9721 0100
Company Email	admin@harveywater.com.au
Chief Executive Officer	Bruce Hathway
CEO Email	admin@harveywater.com.au
DoH Liaison Officers	Cameron Norris and Aled Lewis
DoH Liaison Officer Email	cnorris@harveywater.com.au and alewis@harveywater.com.au

1.1 System Information

1.1.1 Catchment Details

Harvey Water has installed a bore into the Leederville aquifer to supply water for treatment to the Albemarle Lithium processing plant in the Kemerton Industrial Area. Water from the bore is treated through a Water Treatment Plant (WTP) designed to bring in accordance with the Department of Water and Environmental Regulations (DWER), the Department of Health (DoH) and the Australian Drinking Water Guidelines (ADWG).

The bore area is situated on the Swan Coastal Plain, which is formed of shoreline and coastal dune deposits extending from the Darling Scarp to the Indian Ocean. Lakes and swamp occur in the low-lying interdunal depressions. The coastal plain is drained by the Wellesley River and a number of drains which discharge into it. Benger Swamp and Mialla Lagoon are prominent wetlands which occupy large shallow depressions in the coastal plain close to the Darling Scarp. The Wellesley River, the only major watercourse in the vicinity of the site, runs in a south-westerly direction, 2km to the east of the bore area. This is one of the major river systems in the area that flows into the Brunswick River, which ultimately merges with the Collie River prior to discharging into the Leschenault Inlet.

Raw water is pumped to the WTP where it is treated through a system of filters and chemical dosing. Water is initially passed through a 100% glass multimedia filter to remove large particulates from the source water. After the multimedia filtration, water is chlorinated using sodium hypochlorite. Chlorinated water is then passed through a DMI media filter which utilises catalytic filtration media for the removal of iron and manganese.



Figure 1 – Location of Bore and WTP

1.1.2 Distribution System

Chlorination and pH adjustments are undertaken in order to maintain a final free chlorine concentration of between 0.5 – 2.0 mg/L and a pH between 6.5 – 8.5 as per ADWG. Treated potable water is stored in a 200kL storage tank on site prior to pumped distribution around the Albemarle site.

1.1.3 Sampling Schedule & Procedure

Drinking water sampling is carried out in accordance with the Australian Drinking Water Guidelines (ADWG) and the Harvey Water sampling procedure. Free chlorine residual, pH and turbidity are analysed continuously within the potable water treatment plant. Weekly samples of drinkingwater are analysed in a NATA registered laboratory for pH, electrical conductivity, total dissolved solids, total suspended solids, alkalinity, chloride, coliforms, *E. coli*, and amoeba. Further to this, monthly samples are analysed for metals (calcium, magnesium, sodium, iron, cadmium, copper, manganese and lead) hardness, sulphate and nitrate. Annual analysis further expands on the weekly and monthly analysis to include a full suite of metals analysis as well as organic compounds and radiological tests.

Further monitoring or adjustments to the sampling schedule can be made in response to the following:

- Post any incident
- Issues identified during a risk assessment
- Availability of any new information or new industry best practices
- Recommendations from regulatory authorities.

2 Performance Summary

Water Quality Meeting the Drinking Water Guidelines July - Sept 2024			
Parameters	No. of Analyses	No. of Analyses Complying with ADWG	No. of exceedances of ADWG
Microbial Quality			
<i>E. Coli</i>	13	13	0
Thermophilic <i>Naegleria</i>	13	13	0
Chemical and Physical Quality			
Health Related	128	128	0
Aesthetic	74	56	18
Radiological Quality			
Gross Alpha activity	0	0	0
Gross Beta activity	0	0	0

3 Microbial Performance

During the July to September 2024 reporting period, there were no reported exceedances of microbial parameters when compared against the ADWG in the potable water system.

3.1 Microbial – Compliance Summary

Harvey Water Distribution System July – Sept 2024				
Microbial Characteristic	MOU Compliance Criteria	No. of Analyses	No. of Complying Analyses	% Compliance
Bacterial				
<i>E. Coli</i>	Non-detect	13	13	100
Amoeba				
Thermophilic <i>Naegleria</i>	Non-detect	13	13	100

3.2 Microbial – Exception Notifications

During the reporting period of July to September 2024, there were no reported exceedances of microbial characteristics.

4 Chemical – Health Related Performance

During the July to September 2024 reporting period there were zero reported exceedances of the chemical health parameters in accordance with the ADWG.

4.1 Chemical: Health Related – Compliance Summary

Harvey Water Distribution System July – Sept 2024					
Health Characteristic	ADWG Guideline value(mg/L)	No. of Analyses	No. of Analyses Complying with ADWG	% Compliance	Max Value of Analysis (mg/L)
Cadmium	0.002	3	3	100	<0.00001
Chlorine (In house testing free residual)	5	13	13	100	0.93
Copper	2	3	3	100	<0.001
Lead	0.01	3	3	100	<0.001
Manganese	0.5	3	3	100	0.0039
Nitrate	50	3	3	100	0.43

During the July to September reporting period there was no PFAS sampling undertaken due to Harvey Water staff undertaking training for sampling PFAS and awaiting the suitable equipment. PFAS sampling will be conducted in the next quarter.

4.2 Chemical: Health Related – Exception Notifications

During the reporting period of July to September 2024 there were no reported exceedances of health-related chemical characteristics.

5 Chemical – Aesthetic Performance

During the July to September 2024 reporting period, there were two analytes that exceeded the chemical aesthetic parameters in the potable water distribution system. The details of these are outlined in section 5.2. There was no colour data for the reporting period but Harvey Water will conduct colour sampling during the next quarter.

5.1 Chemical – Aesthetic

Harvey Water Distribution System July – Sept 2024					
Aesthetic Characteristic	ADWG guideline value(mg/L unless stated)	No. of Analyses	No. of Analyses Complying with ADWG	% Compliance	Max Value of Analysis (mg/L unless stated)
pH	6.5 – 8.5	13	13	100	8.2
TDS	600	13	2	15	690
Turbidity	5 NTU	13	13	100	0.8 NTU
Sodium	180	3	3	100	130
Hardness	200	3	0	0	250
Chloride	250	13	13	100	220
Sulfate	250	3	3	100	91
Iron	0.3	3	3	100	0.13

5.2 Chemical – Aesthetic – Incident Specific Information

Two analytes exceeded the aesthetic guidelines in a total of 17 samples analysed. These exceedances are discussed below:

- Total Dissolved Solids (TDS) – during this period, the TDS level in the potable water system ranged from 550 – 690 mg/L. It is noted water with TDS in the range of 600 – 900 mg/L is considered to have fair palatability, rather than good palatability for water with TDS < 600mg/L. As the water in this system falls within the fair range, the water quality will continue to be monitored to ensure the quality does not deteriorate further.
- Hardness - Hardness is another parameter that exceeded the aesthetic guideline in accordance with the ADWG. The main issue of concern with hardness is the formation of scaling in pipework. The optimum hardness of potable water is in the range of 60 – 200 mg/L as CaCO₃. The maximum hardness level in this water source recorded during this reporting period was 250 mg/L. According to the ADWG, water with hardness in the range of 200 – 500 mg/L as CaCO₃ will have increasing scaling problems. Harvey Water will continue to monitor the level of hardness in the potable supply to ensure scaling does not pose an issue to the ongoing supply of drinking water to Albemarle.

6 Radiological Performance

6.1 Radiological – Compliance Summary

During the July to September 2024 reporting period, there were no tests conducted for radiological performance as the next test for these will be in the annual sampling conducted in December each year.

Harvey Water Distribution System July – Sept 2024					
Radiological Characteristic	ADWG Screening Criteria (Bq/L)	No. of Analyses	No. of Analyses Complying with ADWG	% Compliance	Max Value of Analysis (Bq/L)
Gross Alpha Activity	0.5	0	0
Gross Beta Activity	0.5	0	0

(Bq/L means becquerels per litre)

7 Planned Sample Summary

7.1 Planned Sample Compliance Summary

Planned Samples July – Sept 2024								
Microbial			Chemical			Radiological		
Planned	Taken	% Taken	Planned	Taken	% Taken	Planned	Taken	% Taken
13	13	100	13	13	100	0	--	--

7.2 Planned Sample Exception Notifications

During the July to September 2024 reporting period there was no missing samples.